# EU - TYPE EXAMINATION CERTIFICATE

SNAS
Reg. No. 058/P-017

**No. SK 17 - 079 MI-003** Rev. 4

*This revision replaces all previous versions of this Certificate in full wording*

| | |
|---|---|
| Issued by | **Slovenská legálna metrológia, n. o.**<br>**Hviezdoslavova 31**<br>**974 01 Banská Bystrica**<br>**Slovak Republic**<br>Notified Body number **1432** |
| In accordance with | Annex II, Module B to Government Ordinance of the Slovak Republic No. 145/2016 Coll. relating to the making available on the market of measuring instruments, which implements, in Slovakia, the Directive 2014/32/EU of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of measuring instruments as later amended (MID). |
| Applicable essential requirements | Annex I and Annex V to MID |
| Manufacturer | **APATOR S.A.**<br>**Ul. Gdańska 4a lok C4**<br>**87-100 Toruń, Poland** |
| Applicant | **Manufacturer** |
| Measuring instrument | **Active electrical energy meter** |

| | |
|---|---|
| Type | **NORAX3D or NORAX3D +** |
| Trade mark | see Descriptive annex |
| SW version | see Descriptive annex |
| Environment classes | |
| - climatic | (-25 to +55) or (-40 to +70) °C |
| - mechanical | M1 or M2 |
| - electromagnetic | E2 |

| | |
|---|---|
| Description and documentation | The principal technical and metrological data, characteristics, instrument description and approval conditions are set out in the Descriptive annex to this EU - type examination certificate (19 pages), which is part of this EU - type examination certificate. The test reports, designs, schematic diagrams and documentation used during certification process are recorded under reference folder Apator_NORAX3D_04. |
| Valid until | **2 May 2027** |
| Date of issue | 10 December 2018 |

assoc. prof. Ing. Jaromír Marković, PhD.
*Representative of Notified Body*

SLOVAK LEGAL METROLOGY SLM 1432

*Where the instrument is subject to other Directives covering other aspects, this EU - type examination certificate is valid, assuming that the instrument conforms to the provisions of those Directives. Without written premission of the notified body this certificate may by reproduced only as a whole.*