



Certificate of Conformity

No. CoC-1902351-01

Applicant : Apator S.A.
ul. Gdańska 4a, lok C4
87-100 Toruń
Poland

Issued by : NMI Certin B.V.
Hugo de Grootplein 1
3314 EG DORDRECHT
The Netherlands

Submitted : **Poly phase static electrical energy meter**

Manufacturer : **APATOR S.A.**
Type : **smartESOX pro**

Characteristics : reference voltage : 3x58/100 V ... 3x230/400 V
reference current : 1 A
maximum current : 6 A
class : 0,2 S for active energy (IEC 62053-22)
destined for the : electrical energy, in a
measurement of : - three-phase four-wire system

In accordance with : - **IEC 62052-11** "Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 11: Metering equipment"
- **IEC 62053-22** "Electricity metering equipment (AC) - Particular requirements - Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)"

The described products are tested according to the above mentioned product standards and meet the essential requirements, based on a non-recurrent examination. The appertaining test data is presented in type evaluation report no. NMI-1901713-01, granted by NMI and test report č.2014/MI-003/B070/002, issued by Laboratórium elektrických veličín.

13 April 2018
NMI Certin B.V.



C. Oosterman
Head Certification Board

NMI Certin BV
Hugo de Grootplein 1
3314 EG Dordrecht
PO Box 394
3300 AJ Dordrecht, NL
T +31 78 6332332
F +31 78 6332309
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

Reproduction of the complete document is permitted.

